



**District Level Water analysis
Laboratory
Uttar Pradesh Jal Nigam (Rural), Kushinagar
Add. -Vill Parsauni Kala Near Water Tank Padrauna
KUSHINAGAR 274304**



TC- 17214

Analysis Report

Report No DL/KSN/AUG/11

Date 20.08.2026

Page No 01

Customer Details

Name and Address J.S. INTERNATIONAL SCHOOL VILL- BENDUAR AHIRALI BAZAR SUKRAULI, KUSHINAGAR
Ref Letter No & Date NA

Basic details of sample

District	KUSHINAGAR	Block	SUKRAULI
Gram Panchayat	BENDUAR AHIRALI BAZAR	Village	BENDUAR AHIRALI BAZAR
Habitation	BENDUAR AHIRALI BAZAR	Location	NEAR KALI MANDIR
Water Source	RO WATER SAMPLE	Sample Id	KSN /11
Quantity of Sample	1000 ml	Date of S.C.	19.08.2026
Receiving Date	19.08.2026	S. Collector	JITENDRA JAISWAL
Sample Depositor	JITENDRA JAISWAL		
Analysis Start Date	20.08.2026	Analysis Completion Date	20.08.2026

Temperature- 25±3°C

Relative Humidity- 50±15%

Technical Data of Analysis

S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values As per BIS 10500:2012			Ref. Method of Analysis
			Unit	Acceptable Limit	Permissible Limit	
1	2	3		4	5	6
1	pH	7.0	---	6.5	8.5	IS 3025(Part 11): 2022
2	Turbidity (NTU)	0.25	NTU	1.0	5.0	IS 3025(Part 10): 2023
3	TDS (mg/l)	136	mg/L	500	2000	IS 3025(Part 16): 2023
4	Total Alkalinity (mg/l)	112	mg/L	200	600	IS 3025(Part 23): 2023
5	Total Hardness (mg/l)	120	mg/L	200	600	IS 3025(Part 21): 2023
6	Calcium (mg/l)	35.6	mg/L	75	200	IS 3025(Part 40): 2019
7	Magnesium (mg/l)	17.49	mg/L	30	100	IS 3025(Part 46): 2019
8	Chloride (mg/l)	30	mg/L	250	1000	IS 3025(Part 32): 2019
9	Odour	Agreeable		Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025(Part 5): 2018
10	Taste	Agreeable		Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025(Part 8): 2023

#BDL- Below Detection Limit, NA- Not Analyzed.

** Parameter(s) above permissible limit are in bold digits.

- Note
1. This Certificate refers only to the particular sample (s) submitted for testing.
 2. This certificate shall not be re produced, except in full, unless written permission for the publication of an approved abstract.
 3. The test results reported in this certificate are valid at the time of under the stated conditions of measurements.
 4. Sample will be stored up to 07days (in case of non-perishable item only) from the date of issue of tests reports.
 - 5* Parameter Are Not NABL accredited

Manish
Prepared by

Email id- labkushinagar@gmail.com

chandan
Reviewed By

Authorized Signatory
Contact No-9120706093





**District Level Water analysis Laboratory,
Uttar Pradesh Jal Nigam (Rural), Kushinagar
Add. -Vill Parsauni Kala Near Water Tank Padrauna
KUSHINAGAR 274304**

BACTERIOLOGICAL SAMPLE TEST REPORT

Report No	DL/KSN/AUG/11	Date	20.08.2026	Page No	01
Customer Details					
Name and Address	J.S. INTERNATIONAL SCHOOL VILL- BENDUAR AHIRALI BAZAR SUKRAULI, KUSHINAGAR				
Ref Letter No & Date	NA				
Basic details of sample					
District	KUSHINAGAR	Block	SUKRAULI		
Gram Panchayat	BENDUAR AHIRALI BAZAR	Village	BENDUAR AHIRALI BAZAR		
Habitation	BENDUAR AHIRALI BAZAR	Location	NEAR KALI MANDIR		
Water Source	RO WATER SAMPLE	Sample Id	KSN /11		
Quantity of Sample	1000 ml	Date of S.C.	19.08.2026		
Receiving Date	19.08.2026	S. Collector	JITENDRA JAISWAL		
Sample Depositor	JITENDRA JAISWAL				
Analysis Start Date	20.08.2026	Analysis Completion Date	20.08.2026		
Temperature- 25±3°C		Relative Humidity- 50±15%			

S. No.	Analyzed Parameters(Unit of Measurement)	Observed Value	Specified Values As per BIS 10500:2012			Ref. Method of Analysis
			Unit	Acceptable Limit	Permissible Limit	
1	2	3		4	5	6
1	pH	7.5	---	6.5	8.5	IS 3025(Part 11): 2022
2	Residual Chlorine	0.0	mg/L	0.2	1.0	IS 3025(Part 26): 1986
3	Total Coliform	0	CFU	0	CFU	APHA 23 Edition ; 2017
4	E- Coli	0	CFU	0	CFU	APHA 23 Edition ; 2017

#BDL- Below Detection Limit, NA- Not Analyzed.

** Parameter(s) above permissible limit are in bold digits.

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
 3. The test results reported in this certificate are valid at the time of under the stated conditions of measurements.
 4. Sample will be stored up to 07 days (in case of non-perishable item only) from the date of issue of tests reports.
 - 5* Parameter Are Not NABL accredited

Manish

Prepared by

Email id- labkushinagar@gmail.com

chandan

Reviewed By



Authorized Signatory

Contact No-9120706093



**District Level Water analysis Laboratory,
Uttar Pradesh Jal Nigam (Rural), Kushinagar
Add. -VillParsauni Kala Near Water Tank Padrauna
KUSHINAGAR 274304**

Analysis Report

Report No DL/KSN/AUG/11

Date 20.08.2026

Page No 01

Customer Details

Name and Address J.S. INTERNATIONAL SCHOOL VILL- BENDUAR AHIRAU LI BAZAR SUKRAULI, KUSHINAGAR
Ref Letter No & Date NA

Basic details of sample

District	KUSHINAGAR	Block	SUKRAULI
Gram Panchayat	BENDUAR AHIRAU LI BAZAR	Village	BENDUAR AHIRAU LI BAZAR
Habitation	BENDUAR AHIRAU LI BAZAR	Location	NEAR KALI MANDIR
Water Source	RO WATER SAMPLE	Sample Id	KSN /11
Quantity of Sample	1000 ml	Date of S.C.	19.08.2026
Receiving Date	19.08.2026	S. Collector	JITENDRA JAISWAL
Sample Depositor	JITENDRA JAISWAL		
Analysis Start Date	20.08.2026	Analysis Completion Date	20.08.2026

Temperature- 25±3°C

Relative Humidity- 50±15%

Technical Data of Analysis

S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values As per BIS 10500:2012			Ref. Method of Analysis
			Unit	Acceptable Limit	Permissible Limit	
1	2	3		4	5	6
11	Fluoride*	0.21	mg/L	5.00	20.0	IS 3025(Part 60): 2022
12	Nitrate (mg/l)*	0.921	mg/L	5.00	50.0	IS 3025(Part 34): 2022
13	Sulphate (mg/l)*	1.989	mg/L	5.00	50.0	IS 3025(Part 24): 2022
14	Iron (mg/l)*	0.00	mg/L	0.50	5.0	IS 3025(Part 53): 2022
15	Arsenic (mg/l)*	0.00	mg/L	0.005	2.00	IS 3025(BY AAS): 2022
16	Conductivity*		(Ms/cm)	NA	NA	IS 3025(Part 10): 2017

#BDL- Below Detection Limit, NA- Not Analyzed.

** Parameter(s) above permissible limit are in bold digits.

- Note
- 1.This Certificate refers only to the particular sample (s) submitted for testing.
 2. This certificate shall not be re produced, except in full, unless written permission for the publication of an approved abstract.
 3. The test results reported in this certificate are valid at the time of under the stated conditions of measurements.
 4. Sample will be stored up to 07days (in case of non-perishable item only) from the date of issue of tests reports.
 - 5* Parameter Are Not NABL accredited

Manish
Prepared by

Email id- labkushinagar@gmail.com

chandan
Reviewed By

Authorized Signatory
Contact No-9120706093

Prabhat Kanjan
(Quality Manager)



Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. DL/KSN/AUG/11

Dated: 20/08/2026

It is certified that an inspection team headed by Neeraj Kumar (A.E.)

(Name of Officers with designation) from U.P. Jal Nigam (Rural) Kushinagar PHED

inspected the J.S. International School Vill- Benduar Ahirauli Bazar Sukrauli Kushinagar

(Name & Address of the school) on 20/08/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. DL/KSN/AUG/11 dated 20/08/2026

of District Water Testing Lab U.P.J.N(R) Kushinagar (PHED Lab) certified that

the J.S. International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 1 Year

Signature with Seal:

Name

Designation

Name & Address of the Office / Department: U.P.J.N(R) Kushinagar

सहायक अभियन्ता

जल निगम ग्रामीण

Neeraj Kumar

A.E. कुशीनगर

To
J.S. International School
Benduar Ahirauli Bazar Sukrauli Kushinagar
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies